

Declaration of Conformity

Henry Technologies hereby declare that the Pressure Equipment listed below has been designed, manufactured and tested in accordance with the requirements of the Pressure Equipment Regulations 1999 (European Directive 97/23/EC)

Description of Pressure Equipment:

Description of Vessel / Assembly: Suction Line Accumulators

Models covered:

(Cat I) S-7057, S-7061,

(Cat II) S-7063, S-7065, S-7721, S-7725

(Including products with "HE" and "HP" suffixes)

Conformity and Assessment Procedure Followed

Category	Cat I	Cat II
Module	A	D1
Certificate		CE-0041-PED-D1-HEN 001- 09 GBR
PV.	50 - 200	200 - 1000

Classified for	Group 2 Gases
Design pressure	31 bar
Maximum Op. Temp	+ 80° C
Minimum Op. Temp	- 25° C

The following transposed European standards and other technical specifications have been used:

UL 207, AD Merkblätter

Notified Body:

The Notified Body which inspected the manufacturer's quality assurance system:

Bureau Veritas UK Ltd.

Parklands

Wilmslow Road

Didsbury

Manchester M20 2RE

Notified Body identification No. **0041**

Signed : *James McCaig*

Quality Director: 23.8.12

(Responsible Person - Name and actual Title)

